

CUMBERLAND HEIGHTS
SPRINKLER SYSTEM RESPONSE PROCEDURE

1. When alarm sounds, go to building indicated.
2. Locate sprinkler head in use and determine reason for activation (i.e., fire, head loose, head knocked off).
3. If no fire is found, go to Sprinkler Valve Room.
 - A. Close valve marked MAIN by turning to the right.
 - B. Open valve marked DRAIN by turning to the left.
 - C. Go to Tank House and push STOP button on panel to the left of entrance door. This will silence the alarm and stop pump (if not already silenced or stopped automatically).

NOTE: Sprinkler system is tied into Simplex and usual steps should be taken.

IMPORTANT: Contact the maintenance person on-call ASAP if any water is discharged by sprinkler system. **PHONE NUMBER 405-7602 or call Scott Adams 615-405-9877 or Russ Taylor 615-495-6915.**

If staff cannot be reached call **Jim Ring** **851-0161**
 Nashville Sprinkler

LOCATION OF SPRINKLER VALVES:

| | |
|--------------------|---|
| Cabins #1 & #2 | Under cabins in Mechanical Room |
| Templeton Hall | Closet next to bathroom at foot of staircase. |
| Medical/First Step | Closet in hallway of Intake |
| Cabana | Closet in room 907 |
| Family Life Center | In pump room basement of building |
| Hazel Hawkins | In utility room basement of building |